

SECTION 3

3.05 COMBINATION SERVICE LINES:

A property requiring a domestic service line and a fireline connection may be served from a single tap in some cases. The fireline connection shall extend straight from the main to the property line and shall have a gate valve located 2 feet minimum from the property line on the street side of the property line. A tee shall be placed on the fireline connection on the inlet side of the gate valve for the domestic service line. No more than one domestic service connection (tap or tee) shall be installed on a fireline connection. A domestic service tee may not be placed on an existing fireline. See Sheet 34 of the Standard Drawings and 6.37 and 8.18.